

Silver Star Water (SSW) Water Quality Report for June 2020

The following is the water quality summary for the Silver Star Water (SSW) Utility.

1. Sources

Not all of Silver Star's water sources are utilized year round; the system is constructed so that the sources can be brought on line based on demand. As Silver Star is primarily a winter resort, the highest water demands occur during November to March. SSW has nine water sources used for domestic use: Well #1, Well#2, Well #3, Well #4, Well #5, Well #10, Well #12, Paradise Reservoir and Vance Reservoir. Paradise and Vance Reservoirs are metered in the Mid-T station as one volume; it is not possible to separate the volumes of each reservoir. Table 1 summarizes the results for bacterial and turbidity for the untreated water at the Mid-T which includes the blended water from the wells and surface sources, and the turbidity of the wells alone. Well 4 and Well 10 have not been used this season.

Table 1 Mid-T Blended Raw Water Monitoring

Parameter	Laboratory		# of Samples	# of Exceedance	Min	Max	Average
E.coli	Caro	Counts/100mL	2	-----	<1	<1	<1
Total Coliform	Caro	CFU/100 mL	2	-----	<1	<1	<1
Turbidity "sample site d"	grab sample	NTU	1	-----	0.16	0.16	0.16
Turbidity of the Wells ²	SCADA ¹ Daily Average	NTU	20 Days	-----	0.01	2.41	0.25

¹SCADA: Supervisory Control and Data Acquisition.

Distribution

SSW monitors contact time. Table 2 summarizes the results for chlorine, turbidity and bacterial for the distribution system from the following sites: Mid T Treated SS "c", Pinnacles, Grandview, Firehall and Maintenance Building. Table 3 summarizes the calculated contact time. Table 4 summarizes the UVT at the Mid-T. The monthly water volume used at Silver Star was approximately 5,293 m³.

Table 2 SSW Distribution

Parameter	Laboratory		# of Samples	# of Exceedance	Min	Max	Average
Free Chlorine ¹	grab sample	mg/L	30	-----	0.94	1.71	1.51
Total Chlorine	grab sample	mg/L	30	-----	1.05	1.82	1.59
Free Chlorine ^{1,2}	SCADA Daily Average	mg/L	30 Days	-----	1.57	1.69	1.62
E.coli	Caro	MPN/100 mL	30	-----	<1	<1	<1
Total Coliform	Caro	CFU/100 mL	30	-----	<1	<1	<1
Turbidity	grab sample	NTU	30	-----	0.08	0.26	0.20
Turbidity Reservoir	SCADA Daily Average	NTU	30 Days	1 ³	0.06	1.92	0.16

¹WQ Deviation Response Plan - Free Chlorine <0.20 mg/L or >2.20 mg/L; Turbidity >1.0 NTU

²Chlorine residual taken 10 meters after chlorination.

³There was one reading of Turbidity >1 NTU on June 10th 2020, turbidity quickly returned to < 1 NTU.

Table 3 SSW – Contact Time (CT)

Parameter	Days Monitored	Min	Max	Average
Days 99.9% achieved	12 Days	100%	100%	100%

99.9% is 3-log removal for Giardia

Table 4 Mid-T UV Transmissivity

Parameter	Laboratory		# of Samples	# of Exceedance	Min	Max	Average
UVT (unfiltered)	grab sample	%	5	-----	100	100	100
UVT (online)	Online Reading	%	5	-----	93.6	96.6	95.5