



**NOTES**

1. 175 mm MINIMUM CLEARANCE BETWEEN WALL AND CENTRELINE OF PIPE
2. METERS MUST BE ACCESSIBLE AND NOT BE LOCATED BEHIND FURNACE, WATER TANK, ETC.
3. METER MAY BE INSTALLED HORIZONTALLY OR VERTICALLY
4. NO TEES OR JUNCTIONS BEFORE METER
5. AT LEAST 0.5m OF ARB CABLE TO BE FOLDED (DO NOT LOOP) AROUND METER
6. ALL PRV, BACKFLOW DEVICE AND METER INSTALLATIONS TO CONFORM TO APPLICABLE CODES AND STANDARDS.
7. MINIMUM 4 WIRE 24 AWG CABLE TO BE USED. 3 WIRES REQUIRED TO BE CONNECTED TO THE METER IN ACCORDANCE WITH MANUFACTURERS SPECIFICATIONS  
ALLOW 2 METRES MIN. OF SLACK ARB CABLE TO BE LOOSE INSIDE CHAMBER IMMEDIATELY UNDER THE LID. FOLD THE ADDITIONAL CABLE. DO NOT COIL.

**REGIONAL DISTRICT  
OF NORTH OKANAGAN**

9848 Aberdeen Road, Coldstream, BC V1B 2K9  
PH: 250-550-3700 FAX: 250-550-3701



**TITLE**  
**TYPICAL WATER METER  
INSTALLATION IN BUILDING**

**DATE**  
OCT. 2015

**SCALE**  
N.T.S.

**DRAWING No.**  
W-15

**REV.**  
3