



REGIONAL DISTRICT OF NORTH OKANAGAN ADDENDUM #1

Tender Number: 2017 E372.17.07.2

**Project Name: Part 'A' – Star Road to Marmot Court Water Main
Part 'B' – School Road Water Main Replacement**

Tender Close Date: Thursday July 06, 2017

Date: June 22, 2017

Please replace the page "Appendix 'G' – To follow as an addendum" with the attached Interior Health Permit.



Interior Health

June 21, 2017

W - 0410814

Regional District of North Okanagan
9848 Aberdeen Road
Vernon BC V1B 2K9

Attention: Sandy Edwards

Re: Construction Permit No. CP2017-47681 for School Road WM Replacement

Enclosed is a Construction Permit issued under Section 7 of the Drinking Water Protection Act authorizing construction of your waterworks. This Permit is valid for one year only and is non-transferable.

It is the responsibility of the water purveyor to ensure that, following completion of construction or repair, all waterworks are disinfected in accordance with the appropriate AWWA standard or equivalent.

Sewers

It is the responsibility of the water purveyor to ensure that water mains under construction or repair are not contaminated by effluent from sewers or storm drains. Interior Health guidelines are as follows:

Wherever possible, mains and laterals are to be laid at least 3 metres (10 feet) horizontally edge-to edge from any sewer or storm drain or, where this horizontal separation is not possible, (where water and sewer lines must cross or share the same trench) the water line shall be at least 45 cm (18 inches) edge-to-edge above the sewer line and to one side of the sewer or, if the vertical separation is not possible, the sewer line shall be of the same service capability as the water line.

Yours truly,

Wayne Radomske, P.Eng
Public Health Engineering

WAR/ch

Encl.

cc Gordon Moseley, EHO, IHA
Ministry of Community, Sport and Cultural Development
Brian Hillson, L.Eng., Gentech Engineering Inc.



Interior Health

Waterworks Construction Permit

This is to certify that, in accordance with Section 7 of the Drinking Water Protection Act, the proposed works have been reviewed and may commence in accordance with the approved plans. See attached.

Water Supply System:	Greater Vernon Water Utility
Address:	9848 Aberdeen Road, Vernon BC
Facility Number:	0410814
Permit Number:	CP2017-47681
Engineer of Record:	Brian Hillson, L.Eng., Gentech Engineering Inc.
Address:	3 – 551 Trans-Canada Hwy NE, Salmon Arm BC
Project Location:	Intersection of School Road and Highway #6
Date of Issue:	June 21, 2017
Date of Expiry:	June 20, 2018



Interior Health

Waterworks Construction Permit

NO. CP2017-47681


TO: Regional District of North Okanagan

THIS IS TO CERTIFY THAT Drawing No. U-01 (rev 0) prepared and submitted by Gentech Engineering portraying the proposed 70m of 200mm CI235 DR18 PVC water main installation at intersection of School Rd and Highway #6, Vernon, BC and submitted in accordance with Section 7 of the Drinking Water Protection Act have been reviewed and the proposed work on the construction, alteration or extension may be commenced in accordance with the approved plan and following conditions.

NOTE: *The system must be constructed in accordance with the plans as approved, or with any modifications that may be subsequently approved by the issuing official in writing.*

This document certifies that the plans and specifications for the proposed works have been reviewed pursuant to the current "Waterworks System Guidelines" issued by the Interior Health and that the plans and specifications meet the health protection requirements outlined in the Guidelines.

The Standards of structural adequacy and safety of the works have not been considered and is not the subject of the Permit.


Public Health Engineer