



NOTES

1. 175 mm MINIMUM CLEARANCE BETWEEN WALL AND CENTRELINE OF PIPE
2. METERS MUST BE ACCESSIBLE AND NOT BE LOCATED BEHIND FURNACE, WATER TANK, ETC.
3. METER MAY BE INSTALLED HORIZONTALLY OR VERTICALLY
4. NO TEES OR JUNCTIONS BEFORE METER
5. AT LEAST 0.5m OF CABLE TO BE FOLDED (DO NOT LOOP) AROUND METER
6. ALL PRV, BACKFLOW DEVICE AND METER INSTALLATIONS TO CONFORM TO APPLICABLE CODES AND STANDARDS.
7. MINIMUM 4 WIRE 24 AWG CABLE TO BE USED. RED, BLACK AND GREEN WIRES TO BE CONNECTED TO CORRESPONDING TERMINALS ON METER.
ALLOW 2 METRES MIN. OF SLACK CABLE. FOLD THE ADDITIONAL CABLE, DO NOT COIL.

REGIONAL DISTRICT
OF NORTH OKANAGAN

9848 Aberdeen Road, Coldstream, BC V1B 2K9
PH: 250-550-3700 FAX: 250-550-3701



TITLE

TYPICAL WATER METER
INSTALLATION IN BUILDING

DATE

OCT. 2015

SCALE

N.T.S.

DRAWING No.

W-15

REV.

3