



# REGIONAL DISTRICT NORTH OKANAGAN

## Mabel Lake Water (MLW) Utility Water Quality Report for May 2022

The following is the water quality summary for the Mabel Lake Water Utility (MLW).

### 1. Source

The MLW system draws raw water from Mabel Lake through a screened intake line to a clear well. Water from the clear well is chlorinated and pumped into a 526 meter long pipe which provides chlorine contact time. Water then flows into the distribution system. Table 1 summarizes the results for bacterial and turbidity for the untreated water at the treatment plant.

**Table 1 Mabel Lake Intake**

Parameter	Laboratory		# of Samples	# of Deviations	Min	Max	Average
E.coli <sup>2</sup>	Caro	CFU/100 mL	5	-----	<1	<1	<1
Total Coliform	Caro	CFU/100 mL	5	-----	<1	<b>1</b>	<1
Turbidity <sup>2</sup>	SCADA <sup>1</sup> Daily Average	NTU	31 Days	-----	0.17	0.38	0.23
Turbidity <sup>1</sup>	Operator Grab Sample	NTU	12	-----	0.16	0.41	0.26
UVT (unfiltered)	GVW	%	4	-----	90.4	91.4	90.9

<sup>1</sup>WQ Deviation Response Plan - Turbidity > 1.0 NTU

<sup>2</sup>Drinking Water Treatment Objectives\_ BC (Sec 4.3): Determine number of raw water samples with E. coli >20 CFU. The number of E. coli in raw water does not exceed 20/100 mL in at least 90% of the weekly samples from the previous six months.

### 2. Treatment Plant

MLW utilizes chlorine disinfection only. Table 2 summarizes the chlorine levels from the pipe that flows into the distribution system.

**Table 2 Mabel Lake Water Treatment**

Parameter	Laboratory		# of Samples	# of Deviations	Min	Max	Average
Free Chlorine <sup>2</sup>	SCADA <sup>1</sup> Daily Average	mg/L	31 Days	-----	1.45	1.62	1.55

<sup>1</sup>SCADA: Supervisory Control and Data Acquisition.

<sup>2</sup>WQ Deviation Response Plan - Free Chlorine <0.20 mg/L or >2.20 mg/L

**3. Distribution**

MLW provides potable water to 3 commercial and 338 residential connections. The majority of connected residents and all 3 commercial connections are seasonally occupied, with approximately 20 connections considered year-round or permanent. The population increases to an estimated one thousand three hundred and fifty (1350) persons during peak summer months.

Table 3 summarizes the results for chlorine, turbidity, and bacteria for the distribution system. The monthly water volume used at Mabel Lake this month was 6,509 m<sup>3</sup>.

**Table 3 Mabel Lake Distribution Parameters**

Parameter	Laboratory		# of Samples	# of Deviations	Min	Max	Average
Free Chlorine	Operator Grab Sample	mg/L	59	-----	0.48	1.74	0.95
Total Chlorine	Operator Grab Sample	mg/L	59	-----	0.59	1.78	1.09
Turbidity	Operator Grab Sample	NTU	59	-----	0.15	0.54	0.28
E.coli	Caro	CFU/100 mL	10	-----	<1	<1	<1
Total Coliform	Caro	CFU/100 mL	10	-----	<1	<1	<1

**4. Customer Calls and Notifications**

Customer calls within the Mabel Lake Water Utility service area are tracked and recorded. There were no customer calls in May.

**5. Operational or Maintenance Activity**

Operational activities within the Mabel Lake Water service area are tracked and recorded. There were 2 distribution operational activities in May. Table 4 outlines the distribution operational and maintenance activities during the month.

**Table 4 Monthly operational work and maintenance**

NUMBER OF LOCATIONS	TYPE OF WORK
0	Hydrant Maintenance
0	Water Service Locate
0	Water Main Break Repair
0	Water Service Install
1	Water Turn On/Off
0	Water Curb Stop Repair
0	Leak Detection
1	Water Service Repair