



Greater Vernon Water (GVW) Water Quality Report for April 2024

1. Sources

GVW has two sources that are used for potable water. The two sources are Duteau Creek and Kalamalka Lake. Raw (untreated) water samples are taken at the intakes of Duteau Creek and Kalamalka Lake once per week. Tables 1 and 2 summarize the results for bacteria and turbidity.

Table 1 Duteau Creek Intake

| Parameter | Laboratory | | # of Samples | # of Deviations | Min | Max | Average |
|------------------------------|---|------------|--------------|-----------------|------|------|---------|
| E.coli³ | Caro | MPN/100 mL | 5 | ----- | <1 | 1 | <1 |
| E.coli³ | RDNO Lab | MPN/100 mL | 10 | ----- | <1 | 5.2 | 1.3 |
| Total Coliform | Caro | MPN/100 mL | 5 | ----- | 25 | 194 | 110 |
| Total Coliform | RDNO Lab | MPN/100 mL | 10 | ----- | 24.9 | 83.3 | 51.8 |
| Turbidity² | GVW WQ Tech | NTU | 5 | ----- | 1.12 | 2.30 | 1.54 |
| Turbidity² | SCADA ¹ Daily Average ⁴ | NTU | 30 Days | ----- | 0.86 | 1.99 | 1.28 |

¹SCADA: Supervisory Control and Data Acquisition.

²Operation Guideline: As outlined in Deviation Response Plan, turbidity <1 NTU.

³Drinking Water Treatment Objectives (Microbiological) for Surface Water Supplies in British Columbia (Sec 4.3): The number of E. coli in raw water samples should not exceed 20/100 mL in at least 90% of the weekly samples from the previous six months.

⁴SCADA data for this online analyzer is an average of 24 readings taken on the hour.

Table 2 Kalamalka Lake Intake

| Parameter | Laboratory | | # of Samples | # of Deviations | Min | Max | Average |
|------------------------|---|------------|--------------|-----------------|------|------|---------|
| E.coli ³ | Caro | MPN/100 mL | 5 | ----- | <1 | 2 | <1 |
| E.coli ³ | RDNO Lab | MPN/100 mL | 10 | ----- | <1 | 1.0 | <1 |
| Total Coliform | Caro | MPN/100 mL | 5 | ----- | <1 | 4 | 2 |
| Total Coliform | RDNO Lab | MPN/100 mL | 10 | ----- | <1 | 5.2 | 1.5 |
| Turbidity ² | GVW WQ Tech | NTU | 5 | ----- | 0.54 | 0.87 | 0.66 |
| Turbidity ² | SCADA ¹ Average ⁴ | NTU | 30 Days | ----- | 0.32 | 0.42 | 0.37 |

¹SCADA: Supervisory Control and Data Acquisition.

²Operation Guideline: As outlined in Deviation Response Plan, turbidity <3 NTU.

³Drinking Water Treatment Objectives (Microbiological) for Surface Water Supplies in British Columbia (Sec 4.3): The number of E. coli in raw water samples should not exceed 20/100 mL in at least 90% of the weekly samples from the previous six months.

⁴SCADA data for this online analyzer is an average of 24 readings taken on the hour.

2. Agriculture/ Irrigation Sources

The sources used for irrigation supply include Duteau Creek, King Edward/Deer Creek, Goose Lake, Coldstream Ranch Well #2 and Well #3. Table 3 summarizes the daily flows for each irrigation system.

The majority of the Duteau Creek water (approx. 85%) is treated. The other sources are separated from the potable system and are not chlorinated.

The irrigation season is from April 15 to September 15. Irrigation water used during the off season is used mainly for livestock watering. This water comes from Ranch Well #2, Ranch Well #3, King Edward and Duteau Creek.

Table 3 Irrigation Volumes for Irrigation Sources over the Month

| Irrigation Sources | DCWTP | Well 3 | Well 2 | King Edward |
|--------------------|----------|--------|--------|-------------|
| Min (ML/Day) | 0.00 | 0.00 | 0.00 | 0.00 |
| Max (ML/Day) | 2067.15 | 0.97 | 0.00 | 1.24 |
| Average (ML/Day) | 427.99 | 0.08 | 0.00 | 0.51 |
| Monthly Total (ML) | 12411.73 | 2.40 | 0.00 | 14.72 |

3. Treatment Plants

GVW has two treatment plants: Duteau Creek Water Treatment Plant (DCWTP) and Mission Hill Water Treatment Plant (MHWTP). At the DCWTP, water is treated with a coagulant and mixed to create a floc before clarification is achieved by Dissolved Air Flotation (DAF). Chlorine is added after clarification to ensure contact time for the removal of viruses, followed by Ultra-violet (UV) disinfection. Finally, an additional dose chlorine is added before entering the distribution system to maintain a set point for the residual chlorine value. MHWTP uses a dual disinfection process of UV and chlorine.

Tables 4 and 6 summarize results for chlorine, bacteria, turbidity, and UV Transmittance (UVT). Table 5 summarizes the log removal of viruses at the DCWTP.

Table 4 Duteau Creek Water Treatment Plant Reservoir

| Parameter | Laboratory | Units | # of Samples | # of Deviations | Min | Max | Average |
|----------------------------|-------------------------------------|------------|--------------|-----------------|-------|-------|---------|
| Free Chlorine ² | SCADA ¹ Daily Average | mg/L | 30 Days | ----- | 1.86 | 2.11 | 1.91 |
| E.coli | Caro | CFU/100 mL | 5 | ----- | <1 | <1 | <1 |
| E.coli | RDNO Lab | MPN/100 mL | 5 | ----- | <1 | <1 | <1 |
| Total Coliform | Caro | CFU/100 mL | 5 | ----- | <1 | <1 | <1 |
| Total Coliform | RDNO Lab | MPN/100 mL | 5 | ----- | <1 | <1 | <1 |
| Turbidity ² | SCADA ¹ Daily Average | NTU | 30 Days | ----- | 0.32 | 0.42 | 0.37 |
| Pre UVT ³ | SCADA ¹ Daily Average | % | 30 Days | ----- | 85.94 | 89.66 | 87.52 |

¹SCADA: Supervisory Control and Data Acquisition.

²Operation Guideline: As outlined in Deviation Response Plan, free chlorine >0.20 mg/L, turbidity <1.0 NTU.

³UVT is monitored pre-UV treatment which is used to determine UV dosage.

This month, no off-spec water occurred at DCWTP.

Table 5 DCWTP – Log Removal of Viruses

| Log Removal of Viruses ¹ | |
|-------------------------------------|---------|
| Days Monitored | 30 Days |
| Days 4-Log Removal Achieved | 30 Days |

¹4-log virus removal logged by the minute on SCADA.

Table 6 Mission Hill Water Treatment Plant

| Parameter | Laboratory | Units | # of Samples | # of Deviations | Min | Max | Average |
|------------------------------|-------------------------------------|------------|--------------|-----------------|-------|-------|---------|
| Free Chlorine | SCADA ¹ Daily Average | mg/L | 30 Days | ----- | 1.94 | 2.02 | 2.00 |
| E.coli | Caro | CFU/100 mL | 5 | ----- | <1 | <1 | <1 |
| E.coli | RDNO Lab | MPN/100 mL | 6 | ----- | <1 | <1 | <1 |
| Total Coliform | Caro | CFU/100 mL | 5 | ----- | <1 | <1 | <1 |
| Total Coliform | RDNO Lab | MPN/100 mL | 6 | ----- | <1 | <1 | <1 |
| Turbidity² | SCADA ¹ Daily Average | NTU | 30 Days | ----- | 0.32 | 0.69 | 0.46 |
| Pre UVT | SCADA ¹ Daily Average | % | 30 Days | ----- | 91.15 | 91.79 | 91.44 |

¹SCADA: Supervisory Control and Data Acquisition.

²Operation Guideline: As outlined in Deviation Response Plan, free chlorine >0.20 mg/L, turbidity <3.0 NTU.

This month, no off-spec water occurred at MHWTP.

4. Distribution

GVW has two distribution systems that interconnect: Duteau System typically supplied by Duteau Creek and Kalamalka System typically supplied by Kalamalka Lake. GVW has approximately 22,350 service connections.

Table 7 summarizes the daily flow for each distribution system. The Duteau and Kalamalka systems have many locations where they can be interconnected. This means there are areas where there is a blend of water quality and can be identified by the conductivity of the water.

Table 7 Volumes for GVW Distribution Systems over the Month

| Volumes | DCWTP | MHWTP |
|---------------------------|--------|--------|
| Min (ML/Day) | 5.20 | 11.85 |
| Max (ML/Day) | 24.10 | 19.76 |
| Average (ML/Day) | 14.71 | 15.60 |
| Monthly Total (ML) | 426.70 | 452.27 |

Tables 8 and 9 summarize results for chlorine, bacteria, and turbidity for each distribution system. These systems are monitored by handheld instruments weekly.

Table 8 Duteau Distribution

| Parameter | Laboratory | | # of Samples | # of Deviations | Min | Max | Average |
|----------------------------|-----------------------|------------|--------------|-----------------|------|------|---------|
| Free Chlorine ¹ | Operator Grab Samples | mg/L | 68 | 2 ³ | 0.03 | 2.04 | 1.05 |
| Total Chlorine | Operator Grab Samples | mg/L | 68 | ----- | 0.10 | 1.97 | 1.38 |
| E.coli | Caro | CFU/100 mL | 23 | ----- | <1 | <1 | <1 |
| E.coli | RDNO lab | MPN/100 mL | 36 | ----- | <1 | <1 | <1 |
| Total Coliform | Caro | CFU/100 mL | 23 | ----- | <1 | <1 | <1 |
| Total Coliform | RDNO Lab | MPN/100 mL | 36 | ----- | <1 | <1 | <1 |
| Turbidity | Operator Grab Samples | NTU | 68 | 1 ³ | 0.3 | 10.6 | 0.75 |

¹GVW WQ Deviation Response Plan: free chlorine >0.20 mg/L, turbidity <1 NTU.

²Sample site was reanalyzed and turbidity <1 NTU.

³Sample site was flushed after reading as part of GVW flushing program

Table 9 Kalamalka Distribution

| Parameter | Laboratory | | # of Samples | # of Deviations | Min | Max | Average |
|----------------------------|-----------------------|------------|--------------|-----------------|------|------|---------|
| Free Chlorine ¹ | Operator Grab Samples | mg/L | 77 | ----- | 0.38 | 2.04 | 1.16 |
| Total Chlorine | Operator Grab Samples | mg/L | 77 | ----- | 0.53 | 2.34 | 1.44 |
| E.coli | Caro | CFU/100 mL | 43 | ----- | <1 | <1 | <1 |
| E.coli | RDNO Lab | MPN/100 mL | 35 | ----- | <1 | <1 | <1 |
| Total Coliform | Caro | CFU/100 MI | 43 | ----- | <1 | <1 | <1 |
| Total Coliform | RDNO Lab | MPN/100 mL | 35 | ----- | <1 | <1 | <1 |
| Turbidity ¹ | Operator Grab Samples | NTU | 77 | ----- | 0.29 | 1.07 | 0.60 |

¹Operation Guidelines: free chlorine >0.20 mg/L, turbidity <3 NTU.

The GVW distribution system contains six sampling sites (Table 10) that frequently have free chlorine <0.2 mg/L due to the sample sites being located at the end of the distribution line. Measures are currently in place to mitigate this issue including regular monitoring and flushing. The three sites at Boss Creek represent a localized area.

Table 10 Low Chlorine Sites and Mitigation Measures

| Frequent Low Free Chlorine Sites | Mitigation Measures |
|--|---------------------------------------|
| O’Keefe Ranch SS | On a localized Water Quality Advisory |
| 9007 Aberdeen Rd SS | Regular monitoring and flushing |
| Noble Canyon B/O | Regular monitoring and flushing |
| Boss Creek PH 1 (Lower) Return/Inlet | Regular monitoring |
| Boss Creek PH 2 (Upper) Discharge/Outlet | Regular monitoring |
| Boss Creek PH 2 (Upper) return/inlet | Regular monitoring |

5. Water Quality and Customer Calls and Notifications

Water Quality Customer calls within the GVW Service area are tracked and recorded. There were a total of 6 customer calls this month.

Table 11 Water Quality Customer Calls for the month

| # of Calls | Type of Call | Issue/Inquiry | Investigation | Comments |
|------------|--------------|--|---------------|--|
| 1 | Information | Water Hardness inquiry | No | Gave average water hardness ranges for both Duteau and Kalamala sources |
| 1 | Issue | High chlorine content in water | No | Customer was advised that chlorine is continuously monitored and is in normal range. Customer will follow up with IH and test independently. |
| 1 | Information | Source water and Treatment questions | No | Customer was directed to website for more information. |
| 1 | Issue | High TSS caused fridge filter to deplete earlier than expected | No | Customer was advised that they were switched to Kalamalka source water which has a higher mineral content. |
| 1 | Information | Customer wanted personal well tested | No | Informed customer that we do not test personal wells. |
| 1 | Information | Customer was wanting to know how much chlorine is in the water | No | Chlorine was deteriorating her pipes. Was advised to check the website. |

6. Operational or Maintenance Activity

Operational activity within the GVW service area are tracked and recorded using an online database. There were a total of 56 operational activities this month outlined in Table 12.

Table 12 Monthly operational work and maintenance for the City of Vernon

| NUMBER OF LOCATIONS | TYPE OF WORK |
|---------------------|----------------------------------|
| 0 | Hydrant Maintenance |
| 0 | Hydrant Maintenance – Corrective |
| 0 | New Hydrant Install |
| 14 | Water Service GIS Locate |
| 2 | Water Main Break Repair |
| 1 | Property Damage Repair |
| 0 | Water Valve Maintenance |
| 4 | Water Valve Repair |
| 17 | Water Service Install |
| 18 | Water Service Repair |
| 0 | Reservoirs Cleaned |
| 0 | New Hydrant Sticker Install |

7. Localized WQA’s and Other Activity

On April 4, 2024, customers were advised that Francis Street would be closed on April 8, 2024, and customers would be without water due to a water main tie in. On April 8, 2024, a precautionary Water Quality Advisory (WQA) was issued for Francis Street due to the water main tie in.

On April 5, 2024, customers located at 4200-4217 34 St were notified that they would be without water on April 9, 2024, due to a planned water main upgrade event.

On April 8, 2024, customers on Dixon Dam Rd, Malim Rd, Brookside Rd, Huges Rd, Hartnell Rd, Curlew Rd and Maddock Rd were notified that they would be without water on April 9, 2024, to accommodate a pump replacement at SBX2 Pump Station

On April 8, 2024, customers on Lakeridge Dr, Lakeridge Crt, Lakeridge Pl, Amber Dr, Jasper Dr, 6676-6848 Cameo Dr, Garnet Rd, Topaz Rd, Jade Rd, 7310-7392 Bella Vista Rd, Ogata Way, Fleming Rd, and Joharon Rd were notified that they would be without water on April 11, 2024 to accommodate maintenance to a Pressure Reducing Valve

On April 11, 2024, the precautionary WQA issued for the Francis Street water main tie in was rescinded.

On April 22, 2024, a precautionary WQA was issued for some customers along De Roo, Briggs and Dixon Dam Roads due to a maintenance event that resulted in a loss of pressure.

On April 30, 2024, a precautionary Boil Water Notice (BWN) was issued for Shantz Road due to an unplanned repair.