

Outback Water System - Water Quality Report for July 2024

1. Source

The Outback water system pumps raw water from Okanagan Lake through a screened intake line to a booster station. The booster station houses the Ultraviolet reactor, sodium hypochlorite injection, instrumentation, and booster pumps to pump water to a two celled reservoir. A raw (untreated) water sample is taken at the intake lake pump station approximately once a month. Table 1 summarizes the results for bacterial, turbidity and UV Transmittance (UVT) for the untreated water at the lake pump station.

Table 1 Outback Intake (untreated)

Parameter	Laboratory		# of Samples	# of Deviations	Result	Min	Max	Average
E.coli¹	Caro	MPN/100 mL	1	-----	<1	-----	-----	-----
E.coli¹	RDNO Lab	MPN/100 mL	1	-----	<1	-----	-----	-----
Total Coliform	Caro	MPN/100 mL	1	-----	1	-----	-----	-----
Total Coliform	RDNO Lab	MPN/100 mL	1	-----	4.1	-----	-----	-----
Turbidity	GVW WQ Tech	NTU	1	-----	0.24	-----	-----	-----

¹Drinking Water Treatment Objectives_ BC (Sec 4.3): The number of E. coli in raw water should not exceed 20/100 mL in at least 90% of the weekly samples from the previous six months.

2. Treatment Plants

The Outback water system uses Ultraviolet (UV) and chlorine disinfection. Table 2 summarizes results for chlorine, bacterial, turbidity, and UV Transmittance (UVT).

Table 2 Outback Water Treatment Plant

Parameter	Laboratory	Units	# of Samples	# of Deviations	Min	Max	Average
Free Chlorine ² (Reservoir)	Operator Grab Sample	mg/L	5	-----	1.28	2.03	1.60
Free Chlorine ² (Reservoir)	SCADA ¹ Daily Average	mg/L	31 Days	-----	1.42	1.85	1.63
Total Chlorine (Reservoir)	Operator Grab Sample	mg/L	5	-----	1.43	2.20	1.76
E.coli (Reservoir)	Caro	CFU/100 mL	5	-----	<1	<1	<1
Total Coliform (Reservoir)	Caro	CFU/100 mL	5	-----	<1	<1	<1
Turbidity ² (Reservoir)	Operator Grab Sample	NTU	5	-----	0.28	0.33	0.31
Turbidity ² (Reservoir)	SCADA ¹ Daily Average	NTU	31 Days	-----	0.16	0.23	0.19
UVT (Unfiltered) Booster ³	SCADA ¹ Daily Average	%	31 Days	-----	86.88	90.46	88.91

¹SCADA: Supervisory Control and Data Acquisition.

²Operational guidelines based on GVW WQ Deviation Response Plan - free chlorine >0.50 mg/L turbidity <1 NTU.

³UVT (Unfiltered) is recorded continuously while booster is both on and off and is not always a representation of the raw water.

3. Distribution

The Outback water system is owned and operated by Greater Vernon Water, a service of the Regional District of North Okanagan. The water system supplies bulk water from the reservoir to the Outback Resort. The Outback Resort water distribution system is a “stand alone system” and the responsibility of the owner/ operator (Strata). Greater Vernon Water does not monitor the water quality in the Outback Resort (Strata). Table 3 summarizes the daily flow rates for the month.

Table 3 Monthly Supply Volumes for Outback System over the Month

Volumes	Outback
Min (ML/Day)	0.00
Max (ML/Day)	0.43
Average (ML/Day)	0.15
Monthly Total (ML)	4.45

4. Water Quality Customer Calls and Notifications

There were no water quality customer calls from the Outback Resort this month.