



REGIONAL DISTRICT NORTH OKANAGAN

Silver Star Water (SSW) Water Quality Report for April 2026

The following is the water quality summary for the Silver Star Water (SSW) Utility.

1. Sources

Not all of Silver Star's water sources are utilized year-round; the system is constructed so that the sources can be brought online based on demand. As Silver Star is primarily a winter resort, the highest water demands occur from November to March. SSW has nine water sources used for domestic use: Well 1, Well 2, Well 3, Well 4, Well 5, Well 10, Well 12, Paradise Reservoir and Vance Reservoir.

The surface water sources, Paradise and Vance Reservoirs, are metered in the Mid T Water Treatment Plant (MTWTP) as one volume; it is not possible to separate the volumes of each reservoir.

Table 1 summarizes the results of the raw water entering the treatment process. This is a blend of sources depending on demands in the system. This results in data variation throughout the year. Table 2 summarizes the results for the untreated water from the wells. Table 3 summarizes the results for the untreated water from Paradise and/or Vance Reservoirs.

Wells 4 and 10 have not been used this season. Vance Reservoir was brought online on November 17, 2025.

Table 1 Mid T Raw Water Monitoring

Parameter	Laboratory		# of Samples	# of Deviations ¹	Min	Max	Average
E.coli	RDNO Lab	MPN/100 mL	4	-----	<1	<1	<1
Total Coliform	RDNO Lab	MPN/100 mL	4	-----	<1	<1	<1
Turbidity	Grab sample	NTU	21	-----	0.23	0.61	0.39
Turbidity	SCADA ² Daily Average	NTU	30	-----	0.28	0.60	0.37

¹SSW WQ Deviation Response Plan – Turbidity >1.0 NTU

²SCADA: Supervisory Control and Data Acquisition.

Table 2 Mid T Raw Water Monitoring – Wells

Parameter	Laboratory		# of Samples	# of Deviations ¹	Min	Max	Average
Turbidity	SCADA ² Daily Average	NTU	30	-----	0.57	1.42	1.02

¹SSW WQ Deviation Response Plan – Turbidity >1.0 NTU

²SCADA: Supervisory Control and Data Acquisition.

Table 3 Mid T Raw Water Monitoring – Surface Sources

Parameter	Laboratory		# of Samples	# of Deviations ¹	Min	Max	Average
E.coli	RDNO Lab	MPN/100 mL	4	-----	<1	<1	<1
Total Coliform	RDNO Lab	MPN/100 mL	4	-----	<1	2	0.5
Turbidity	Grab sample	NTU	4	-----	0.36	0.61	0.44
Turbidity	SCADA ² Daily Average	NTU	30	2 ³	0.32	1.10	0.56
UVT - Unfiltered	RDNO Lab	%	4	-----	94.8	96.7	95.9

¹SSW WQ Deviation Response Plan – Turbidity >1.0 NTU

²SCADA: Supervisory Control and Data Acquisition.

³Daily average turbidity >1.0 NTU on April 26 and 27. Turbidity increase likely due to increased runoff entering Vance reservoir. The blended raw water entering the treatment process remained < 1 NTU.

2. Treatment Plant

SSW has a treatment plant, the Mid T Water Treatment Plant (MTWTP). The MTWTP uses a dual disinfection process of Ultra-violet (UV) disinfection and chlorine. Chlorine is added after UV treatment to ensure contact time for the removal of viruses. Tables 4, 5, and 6 summarize the results for chlorine, bacterial, turbidity, manganese, calculated contact time, and UV transmittance (UVT).

Table 4 Mid T Water Treatment Plant

Parameter	Laboratory		# of Samples	# of Deviations ¹	Min	Max	Average
Free Chlorine	SCADA ² Daily Average	mg/L	30	-----	1.39	1.61	1.46
Free Chlorine	Grab sample	mg/L	4	-----	1.50	1.61	1.56
Total Chlorine	Grab sample	mg/L	4	-----	1.57	1.68	1.63
E.coli	RDNO Lab	MPN/100 mL	8 ³	-----	<1	<1	<1
Total Coliform	RDNO Lab	MPN/100 mL	8 ³	-----	<1	<1	<1
Turbidity	SCADA ² Daily Average	NTU	30	-----	0.25	0.38	0.29
Turbidity	Grab sample	NTU	4	-----	0.27	0.41	0.33
Manganese	RDNO Lab	mg/L	4	-----	0.009	0.013	0.011

¹SSW WQ Deviation Response Plan – Free Chlorine <0.20 mg/L, Turbidity >1.0 NTU, Manganese >0.12 mg/L

²SCADA: Supervisory Control and Data Acquisition.

³Treatment Plant and Distribution bacterial samples are included in the required monthly bacterial sampling amounts as per Drinking Water Protection Regulations Schedule B.

Table 5 Contact Time (CT)

Parameter	Days Monitored	Min	Max	Average
Days 99.9% achieved	4	100%	100%	100%

99.9% is 3-log removal for Giardia

Table 6 Ultra-violet (UV) Disinfection

Parameter	Laboratory	Days Monitored	Min	Max	Average
UVT	SCADA ¹ Daily Average	30	89%	99%	98%

¹SCADA: Supervisory Control and Data Acquisition.

3. Distribution

Table 7 summarizes the results for chlorine, turbidity and bacterial for the distribution system from the following sites: Pinnacles, Grandview, Firehall, and Maintenance Building. The monthly water volume used at Silver Star was 9,166 m³.

Table 7 Distribution

Parameter	Laboratory		# of Samples	# of Deviations ¹	Min	Max	Average
Free Chlorine	Grab sample	mg/L	11	-----	0.63	1.58	1.35
Total Chlorine	Grab sample	mg/L	11	-----	0.71	1.62	1.41
E.coli	RDNO Lab	MPN/100 mL	10 ²	-----	<1	<1	<1
Total Coliform	RDNO Lab	MPN/100 mL	10 ²	-----	<1	<1	<1
Turbidity	Grab sample	NTU	10	-----	0.12	0.33	0.23

¹SSW WQ Deviation Response Plan – Free Chlorine <0.20 mg/L, Turbidity >1.0 NTU

²Treatment Plant and Distribution bacterial samples are included in the required monthly bacterial sampling amounts as per Drinking Water Protection Regulations Schedule B.

4. Customer Calls and Notifications

Customer calls within the Silver Star Water Utility service area are tracked and recorded. Table 8 summarizes the customer calls this month.

Table 8 Customer Calls

# of Calls	Type of Call	Issue/Inquiry	Investigation	Comments
1	Inquiry	Service Requirements	Yes	Developer inquiring about water service requirements upon development
1	Report	Water Pooling	Yes	Customer reported water coming up on the road. Operator determined the water was groundwater.

5. Operational or Maintenance Activity

Operational activities within the Silver Star Water service area are tracked and recorded.

Table 8 summarizes the operational activities this month.

Table 8 Monthly Operational Work and Maintenance

NUMBER OF LOCATIONS	TYPE OF WORK
0	Hydrant Maintenance
0	Hydrant Box Rental
0	Water Service Locate
0	Water Main Break Repair
0	Water Service Install/Inspection
0	Water Turn On/Off
0	Water Service and/or Curb Stop Repair
1	Water Investigation
0	Reservoir Cleaning
0	Water Meter Install
1	Water Meter Inspection
0	Water Meter Maintenance
1	Water Meter Replacement
5	Water Meter Manual Read
1	ERT Install
0	ERT Inspection
0	ERT Maintenance
0	ERT Replacement